

STATEMENT ACCOMPANYING FORM 'A'

1. Door Number of the building : **ST. THOMAS CBSE SCHOOL**
2. Location (Street No. Ward No., Name of Place, (ie Corporation/Municipality), Panchayat/Panchayat Union/ Township/ Cantonment : Alagesapuram Main Road,
T.S.No:4781 pt., Ward No:4, Block No:41,
Thoothukudi.
3. Year of Construction : 2008
4. Approximate cost of construction as per current rates : Rs. 125.00 Lakh
5. Purpose for which the building is being used or proposed to be used : For accommodating a school.
6. Purpose for which building has hitherto been used : For accommodating a school.
7. Details of construction of the building (Particulars of the foundation soil, specification of the various part under)
- (1) Foundation : Isolated spread footing for column foundation.
- (2) Basement : Plinth beam connecting all columns at GL.
- (3) Superstructure : Brick panel wall in CM.
- (4) Floor and roof are to be given : Granite flooring and RCC roofing at GF, FF & SF.
8. Period for which license is required : 21.03.2022 to 20.03.2025
9. Number of persons to be accommodated : 1800

CERTIFICATE PRESCRIBED

"Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made, I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is changed or altered subsequently'.

Signature of the owner of the Building

Date: 21.03.2022

Place: Thoothukudi

Signature of the Dist. Panel Engineer (Class - 1A)

A.ARMSTRONG, B.E., MBA., MIE., FIV.,
DISTRICT PANEL ENGINEER - CLASS' - 1A
20M/2, SUBBIAHPURAM, 1st STREET
THOOTHUKUDI-628 003.
Cell: 9487211267 / 97918 79115

FORM 'B'

Form of certificate of structural soundness under Sub-Section (4) of Section 4 of the Tamil Nadu Public Buildings (Licensing) Act. 1965 Tamil Nadu Act 13 of 1965 referred to in rule 4 of Tamil Nadu Public Buildings (Licensing) Rules, 1966 and G.O. M.S. No. 393 School Education School Education Department dated 11.09.1997.

I Certify that I have inspected the buildings mentioned in the statement and furnish below its salient technical features:-
ST. THOMAS CBSE SCHOOL


1. Foundation

- | | |
|---|---------------------------|
| i. Depth below ground level | ... 2.50 m |
| ii. Nature of soil met with at foundation level | ... sandy soil |
| iii. Pressure at foundation | ... 9.50 t/m ² |
| iv. Probable safe bearing capacity of the strata met with at foundation | ... 20.0 t/m ² |

2. Superstructure

- | | |
|--|-----------------------------|
| i. Maximum stress in the most critical Section of masonry and concrete | ... 48.87 N/mm ² |
| ii. Nature of masonry and its safe permissible Stress | ... 66.0 N/mm ² |

The structural soundness of the building has been verified by me with reference to Indian Standard Institute Loading standards 875 (latest version) and other relevant Indian Standard Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement, A license may be granted for the period from 21.03.2022 to 20.03.2025. Both the days inclusive.


21/3/2022

Date: 21.03.2022

Signature of the Dist. Panel Engineer(Class-1A)

A.ARMSTRONG, B.E., MBA., FIV., MISTE.
DISTRICT PANEL ENGINEER - CLASS - 1A
20M/2, SUBBIAHPURAM, 1st STREET
THOOTHUKUDI-628 003.
Cell: 9487211267 / 97918 79115

Registration No.: D.Dis/C5 31864/2015

Category :Class -1A

District Collector, Thoothukudi District.

Address :A.ARMSTRONG B.E., MBA., FIV., MISTE.

DIST. PANEL ENGINEER & CHARTERED ENGINEER,
Subbiah puram, 1st-Street,
Thoothukudi-628 003.

Cell : 0-9487211267

0-9791879115

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door Number, Street & Name of the Place	Age of Building	Number of Storey	Short Description Structures steel – RCC Framed or load bearing Masonry	Purpose for which the Building is certified for use	The period For which the building is certified for use	Number of Persons to be Accommodated	Remarks
ST. THOMAS CBSE SCHOOL Alagesapuram Main Road, T.S.No:4781 pt., Ward No:4, Block No:41, Thoothukudi.	14 year	GF+2 only	RCC framed structure with brick panel wall with cement mortar. Country wood doors and windows. Marbonite flooring and RCC roofing at GF, FF & SF.	For Conducting Class Room & Lab	21.03.2022 to 20.03.2025	1800	Building is structurally sound

FORM 'C' DECLARATION

A.Armstrong, normally officiating at D.No: 20M/2, Subbiahpuram -1 St Street, Thoothukudi-3, do hereby declare that I possess the qualification and Experience specified in the table to rule II of the Madras Public Building Licensing Act. 1966 for issuing the certificate of structural soundness of the building covered by this certificate.

Signature of the Dist. Panel Engineer(Class-1A)

[Signature]
21/3/2022

Registration No.: D.Dis/C5 31864/2015

Category :Class -1A

District Collector,Thoothukudi District.

Address :A.ARMSTRONG B.E., MBA., FIV.,MISTE.

DIST. PANEL ENGINEER &CHARTERED ENGINEER,

Subbiah puram,1st-Street,

Thoothukudi-628 003.

Cell : 0-9487211267

0-9791879115

**A.ARMSTRONG, B.E., MBA.,MIE.,FIV.,
DISTRICT PANEL ENGINEER-CLASS' -1A
20M/2, SUBBIAHPURAM, 1st STREET
THOOTHUKUDI-628 003.
Cell: 9487211267 / 97918 79115**

FORM 'E'

Form of report to be made to the Competent Authority by Inspecting Authorities of Officers appointed under section 28 of the Madras Building (Licensing) Act 1965 referred to in the rule 7 of the Madras Public Buildings (Licensing) Rule 1966.

- | | | |
|---|---|--|
| 1 | Name and Designation of the Inspecting Authority of Officer appointed or having Jurisdiction under any other Act or Rule | A.ARMSTRONG B.E., MBA., FIV., MISTE.
DIST. PANEL ENGINEER & CHARTERED ENGINEER,
Subbiah puram, 1 st -Street, Thoothukudi-628 003. |
| 2 | Location of the Building inspected (Door No:/ Street No:/ Name of place, i.e. Municipal Corporation/ Municipality, Panchayat/ Panchayat Union/ Township/Cantonment) | ST. THOMAS CBSE SCHOOL,
Alagesapuram Main Road,
T.S.No:4781 pt., Ward No:4, Block No:41,
Thoothukudi. |
| 3 | Date of Inspection | 19.03.2022 |
| 4 | Purpose for which the building is being used or proposed to be used | For accommodating a school |
| 5 | Nature of defects noticed | No Defects |
| 6 | Suggestions for rectifying defects | Not Applicable |
| 7 | If in dangerous condition, immediate steps recommended to be taken | No |

Date: 21.03.2022

Place: Thoothukudi

Signature of the Dist. Panel Engineer(Class -1A)


A.ARMSTRONG, B.E., MBA., MIE., FIV.
DISTRICT PANEL ENGINEER - CLASS -1A
20M/2, SUBBIAHPURAM, 1st STREET
THOOTHUKUDI-628 003.
Cell: 9487211267 / 97918 79115